The VT on the transformer side can be placed on the primary **or** the secondary/ tertiary side.

All the analogue signals can be received by the E2-TRIM_PoW device also from low-power instrument transformers (sensors) with CVS modules.

Edited by:	Seida	Platform:	**EuroProt+**
Checked by:		Type:	**DAUT**
Approved by:		Configuration:	**E2-TRIM_PoW_F**
		Subject:	**Connections between the VT, CT and the E2-TRIM_PoW_F device for switching of transformers**
Date	2024-01-09	ID	**PP-14-22660-03**
		Page:1/1	