



All the analogue signals can be received by the E2-TRIM\_PoW device also from low-power instrument transformers (sensors) with CVS modules.

Edited by	Seida	Platform	<div>EuroProt+ DAUT E2-TRIM-PoW_F</div>		<div><div>PROTECT</div><div>HUNGARY</div><div></div></div>		
Checked		Type					
Approved		Configuration					
		Subject	Connections between the VT, CT and the E2-TRIM-PoW_F device for switching of lines, cables, capacitor banks and shunt reactors			ID	PP-14-22659-03
Date	2024-01-09				Page:1/1		